
CEMS Automation Field Evaluation

San Diego, CA

May 16, 2003

Russell S. Berry

RMB Consulting & Research, Inc.

Introduction

- ◆ 50 - 70% of a CEMS Technician's Time Can be Eliminated
- ◆ Time Currently Spent Recording Pressures, Temperatures, Flow Rates, etc. on Daily Logs

Introduction

- ◆ Current Practices Provide Limited Benefit for Dedicated CEMS Technicians
- ◆ EVEN LESS for “Non-dedicated” Personnel
- ◆ Information becomes “Lost” in CEMS Files or Maintenance Logs

Solution -- Automate

- ◆ Let the Computer do the Recordkeeping & Trending
- ◆ Let the Technicians do the Maintenance
- ◆ All of the Important Data Points can be Recorded Electronically
- ◆ All of the Data Points can be Assigned Meaningful Warning and Alarm Limits
- ◆ If not, the Data Probably Should not be Recorded

Automation Implementation

- ◆ Is it too good to be true?
 - Will it just be another headache?
- ◆ Worth a Try! Depending on \$
- ◆ Midland Cogeneration Venture and RMB Decided to Give Automation a Try
- ◆ Seemed Smart to Try Automating a CT CEMS First
- ◆ Included an Automation Option in the Bid Specification
- ◆ Incremental Cost -- \approx \$20K for all 12 CEMS

Automation Implementation

- ◆ 12 Combined Cycle Combustion Turbines
 - Located in Midland Michigan
 - ABB 11NM, Gas-fired
 - Use Steam Injection
 - 6 With Duct Burners
 - 1 With Low NO_x Burners
 - 6 Rated at 103 MW
 - 5 Rated at 127 MW
 - 1 Rated at 117 MW

Automation Implementation

- ◆ All 12 CEMS are Identical (Except for NO_x Ranges)
 - All 12 CEMS are 50:1 dilution CEMS
 - Monitoring for NO_x and CO₂ with Appendix D
 - All Equipment, DAHS Software and Automation Software was Provided by Spectrum Systems
- ◆ CEMS are Housed in a Total of Three Shelters
 - Four CEMS per Shelter

Operating Parameters

Parameter
Unit online/offline
Unit load
Zero-level calibration gas pressure
High-level calibration gas pressure
Dilution air pressure
Orifice vacuum
Sample flow
Umbilical temperature
Probe temperature
Orifice pressure
Calibration status (pass/fail) for each analyzer
Water-to-fuel ratio
NO _x cooler temperature
NO _x converter temperature
NO _x reaction chamber temperature
NO _x sample pressure
CO ₂ S/R ratio*
CO ₂ light intensities (4 values)*
CO ₂ sample pressure*
CO ₂ sample cell temperature*

Misc. Inputs Page	Unit 3	Unit 4	Unit 5	Unit 6
Turbine Status	Online	Offline	Online	Online
Generator Load: MW	93.7	-0.1	93.98	93.98
NOx Mass: lb/hr	103.21	0.00	75.24	96.03
NOx Rate: lb/mmBtu	0.104	0.000	0.076	0.097
Gas Flow : scfm	16421.0	-32.0	16579.0	16537.0
Steam Injection : kpph	100.2	-0.1	100.3	99.9
Heat Input: mmBtu/hr	985.0	0.0	994.0	995.0

05/06/2003

Alarms	Unit 3
NOx High	CABLE Compensated
NOx	CABLE Compensated
CO2	CABLE Compensated

Alarms	Unit 4
NOx High	Blow Back in Progress
NOx	Blow Back in Progress
CO2	Blow Back in Progress

Alarms	Unit 5
NOx High	CABLE Compensated
NOx	CABLE Compensated
CO2	CABLE Compensated

Alarms	Unit 6
NOx High	CABLE Compensated
NOx	CABLE Compensated
CO2	CABLE Compensated

TECO Analyzers

PMT Cooler Temp. : deg C	-2.50	-2.40	-2.20	-2.40
Convertor Temp. : deg C	315.0	319.0	316.0	328.0
Reaction Chamber Temp. : deg C	50.1	49.9	50.2	49.9
Reaction Chamber Press. : mmHg	214.4	200.4	207.0	216.3
PMT Voltage : volts	-844.0	-835.0	-792.0	-725.0
Sample Flow : l/m	0.60	0.61	0.68	0.65

Date	Time	Monitor	Message
05/06/2003	75405	NOXH2	05/06/03 07:53:00 NOXH2 SPAN passed M: 448.3 E: 447.8
05/06/2003	83032	SF4	Unit 6 Sample line temperature out of range
05/06/2003	83102	CEMSFLT1	Fault: CEMS Fault
05/06/2003	83102	SF4	Unit 6 Sample line temperature OK
05/06/2003	83142	CEMSFLT1	Fault: CEMS Ok

Return to Summary

	Unit 3	Unit 4	Unit 5	Unit 6
Probe Pressure: in WC	-0.62	0.56	-0.72	-0.94
Probe Vacuum: in Hg	22.80	23.13	23.18	23.05
Sample Line Temp: Deg F	125.24	124.07	124.58	125.02
Dil. Air Pressure: psig	49.78	48.75	45.87	54.59
Stack Probe Temp: Deg F	250.1	249.76	249.83	250.49
Diluted Sample Flow: l/m	8.328	8.624	7.885	8.558

Barometric Pressure: in Hg	29.17
Cal Gas 1 Pressure : psig	1215.1
Cal Gas 2 Pressure : psig	1784.2
Daily Zero Gas Pressure : psig	89.5

05/06/2003

Alarms **Unit 3**

- NOx High** CABLE Compensated
- NOx** CABLE Compensated
- CO2** CABLE Compensated

Alarms **Unit 4**

- NOx High** Blow Back in Progress
- NOx** Blow Back in Progress
- CO2** Blow Back in Progress

Alarms **Unit 5**

- NOx High** CABLE Compensated
- NOx** CABLE Compensated
- CO2** CABLE Compensated

Alarms **Unit 6**

- NOx High** CABLE Compensated
- NOx** CABLE Compensated
- CO2** CABLE Compensated

Date	Time	Monitor	Message
05/06/2003	75405	NOXH2	05/06/03 07:53:00 NOXH2 SPAN passed M: 448.3 E: 447.8
05/06/2003	83032	SF4	Unit 6 Sample line temperature out of range
05/06/2003	83102	CEMSFLT1	Fault: CEMS Fault
05/06/2003	83102	SF4	Unit 6 Sample line temperature OK
05/06/2003	83142	CEMSFLT1	Fault: CEMS Ok

Return to Summary

Alarms Unit 3

05/06/2003

Power Fault	HVAC Power	HVAC 2nd Stage
Room Temp Low	Room Temp High	Room Smoke
Sample Moisture	Air Fault (PS1)	Air Fault (PS2)
	UPS Fault	
Probe Temp	Sample Line Temp	
NOx Analyzer		CO2 Analyzer
NOx Cals		CO2 Cals

Alarms	Unit 3
NOx High	CABLE Compensated
NOx	CABLE Compensated
CO2	CABLE Compensated
Alarms	Unit 4
NOx High	Blow Back in Progress
NOx	Blow Back in Progress
CO2	Blow Back in Progress
Alarms	Unit 5
NOx High	CABLE Compensated
NOx	CABLE Compensated
CO2	CABLE Compensated
Alarms	Unit 6
NOx High	CABLE Compensated
NOx	CABLE Compensated
CO2	CABLE Compensated

Date	Time	Monitor	Message
05/06/2003	75405	NOXH2	05/06/03 07:53:00 NOXH2 SPAN passed M: 448.3 E: 447.8
05/06/2003	83032	SF4	Unit 6 Sample line temperature out of range
05/06/2003	83102	CEMSFLT1	Fault: CEMS Fault
05/06/2003	83102	SF4	Unit 6 Sample line temperature OK
05/06/2003	83142	CEMSFLT1	Fault: CEMS Ok

Daily Log

Date	Time	Monitor	Message
05/06/2003	73804	NOX2	05/06/03 07:37:30 NOX2 SPAN passed M: 90.2 E: 90.4
05/06/2003	73941	ZERO2	Unit 4 NOx,CO2 Zero Calibration in Progress
05/06/2003	74421	SPAN2	Unit 4 NOx,CO2 Span Calibration in Progress
05/06/2003	74421	ZERO2	Unit 4 NOx,CO2 Zero Calibration done
05/06/2003	74532	CO22	05/06/03 07:44:00 CO22 ZERO passed M: -0.0 E: 0.0
05/06/2003	74532	NOX2	05/06/03 07:44:00 NOX2 ZERO passed M: 0.3 E: 0.0
05/06/2003	74532	NOXH2	05/06/03 07:44:00 NOXH2 ZERO passed M: -0.1 E: 0.0
05/06/2003	74851	SPAN2	Unit 4 NOx,CO2 Span Calibration done
05/06/2003	74851	SPANH2	Unit 4 High NOx Span Calibration in Progress
05/06/2003	74948	CO22	05/06/03 07:48:30 CO22 SPAN passed M: 9.0 E: 8.8
05/06/2003	74949	NOX2	05/06/03 07:48:30 NOX2 SPAN passed M: 90.3 E: 90.4
05/06/2003	75321	SPANH2	Unit 4 High NOx Span Calibration done
05/06/2003	75405	NOXH2	05/06/03 07:53:00 NOXH2 SPAN passed M: 448.3 E: 447.8
05/06/2003	83032	SF4	Unit 6 Sample line temperature out of range
05/06/2003	83102	CEMSFLT1	Fault: CEMS Fault
05/06/2003	83102	SF4	Unit 6 Sample line temperature OK
05/06/2003	83142	CEMSFLT1	Fault: CEMS Ok

Click Search or type to Filter/Search

Filter OFF

Comments

05/06/2003
CEMSFLT1

Search on Date
Search on Monitor

Up
Up

Down
Down

Filter on Date
Filter on Monitor

[Empty yellow comment box]



Automation Software

- ◆ Has User Configurable Warning and Alarm Limits
- ◆ Monitors Parameters Continuously
- ◆ Saves Hourly Averages Long-term
- ◆ Accessible From Plant-wide Network
- ◆ Stores User-specified Hourly Average for Daily Log
- ◆ Can Save Daily Logs Electronically and/or Print the Daily Records for Hardcopy Filing.

Conclusions

- ◆ Significantly Reduces Recordkeeping Effort, While Significantly Increasing the Value of the Information Being Recorded
- ◆ Currently Using 1 Technician for 12 Turbines -- With 2 Backup Personnel
- ◆ Improves O&M Efficiency and Prioritization
- ◆ Provides Valuable Diagnostic Assistance
- ◆ REDUCES CEMS PROGRAM COSTS

Ongoing Activities

- ◆ EPRI will be Conducting Follow-up Activities to Refine Previously Developed Guidance on CEMS Automation Implementation and to Assess the Type and Design of Equipment Used to Automate CEMS
- ◆ NEXT STOP -- COAL-FIRED UNITS